



Report No: 2021070122
Applicant: AGENCIA DE ENERGIA ALTERNATIVA 2020SL
CL Almoradives 17, Casa 25 CINUELCIA R16, 03189 ORIHUELA COSTA ALICANTE, (SPAIN)
Contact Person: EERO HANIKAT
Contact Telephone: +372 5656 0484
Contact e-mail: info@eae2020.eu / eerohanikat@gmail.com
Sample Accepted on: 17.06.2021
Report Date: 01.07.2021
Total number of pages: 1 (pg)

Sample ID: WALL
PROHYDROSTOP

	TEST	METHOD	SIPECIMEN	RESULT
*	Solar Reflectance	EN 410	WALL	88.43 %
*	Solar Reflectance	EN 410	PROHYDROSTOP	88.75 %



Seal

Customer Representative
Hasan KUTLULaboratory Manager
Hava Sariaydin